



PIPE ID CONTROL SYSTEM

RF096-35/55-100 Series

User's manual

22, Logoisky tract, Minsk
220090, Republic of Belarus
tel/fax: +375 17 357 36 57
info@riftek.com
www.riftek.com

Contents

1.	Safety precautions.....	3
2.	CE compliance.....	3
3.	Laser safety.....	3
4.	General information.....	3
5.	Basic technical data.....	4
6.	Example of item designation when ordering.....	4
7.	Structure and operating principle.....	5
8.	Connection.....	5
9.	Network configuration.....	6
9.1.	PC.....	6
9.2.	PLC.....	8
9.3.	I-7580 module.....	11
10.	GSD import.....	12
11.	Project setup.....	14
12.	Communication.....	21
12.1.	Communication sequence.....	21
12.2.	PROFINET Input Data Area.....	22
12.2.1.	"Interval time" mode.....	22
12.2.2.	"Fixed data length" mode.....	22
12.2.3.	"End character" mode.....	23
12.3.	PROFINET Output Data Area.....	23
12.3.1.	Data output command (byte 1).....	24
12.3.2.	Control bit (byte 2).....	24
12.3.3.	Output data length (byte 3, byte 4).....	24
12.3.4.	Fixed data length (byte 5, byte 6).....	25
12.3.5.	Interval time (byte 7).....	25
12.3.6.	Timeout value (byte 8).....	25
12.4.	Communication between PLC and system.....	26
12.4.1.	General information.....	26
12.4.2.	Data transfer.....	27
12.4.3.	Calibration.....	27
12.4.4.	Measurement.....	27
12.4.5.	Go to zero.....	27
12.5.	Communication tests.....	28
12.6.	Diagnostic messages.....	30
12.6.1.	Output Data Error.....	30
12.6.2.	Input Data Error.....	30
13.	Intended use.....	30
13.1.	Preparation for use.....	30
13.2.	Measurements.....	30
14.	Technical support.....	31
15.	Warranty policy.....	31
16.	Revisions.....	31
17.	Distributors	31

1. Safety precautions

- Use supply voltage and interfaces indicated in the system specifications.
- In connection/disconnection of cables, the system power must be switched off.
- Do not use the system in locations close to powerful light sources.


2. CE compliance

The system has been developed for use in industry and meets the requirements of the following Directives:

- EU directive 2014/30/EU. Electromagnetic compatibility (EMC).
- EU directive 2011/65/EU, "RoHS" category 9.

3. Laser safety

The system makes use of an c.w. 660 nm wavelength semiconductor laser. Maximum output power is 1 mW. The system belongs to the 2 laser safety class according to IEC/EN 60825-1:2014. The following warning label is placed on the housing:



The following safety measures should be taken while operating the system:

- Do not target the laser beam to humans.
- Do not disassemble the laser sensor.
- Avoid staring into the laser beam.

4. General information

The system is designed for non-contact scanning and inner diameter measurement of the pipes.

5. Basic technical data

Parameter	Value	
Measured ID range, mm	35...55	
ID measurement accuracy, mm	±0.05	
Angle scan resolution, points for turnover	3200	
Pipe depth, mm	100	
Linear translation accuracy, mm	±0.05	
Laser sensor linearity, µm	±15	
Laser sensor resolution, µm	3	
Laser sensor sample frequency, Hz	9400	
Light source	red semiconductor laser, 660 nm wavelength	
Laser sensor output power, mW	1	
Laser safety class	2 (IEC60825-1)	
Interface	Ethernet and PROFINET	
Power supply, V	220	
Measurement time, s	<5	
Environmental resistance	Vibration	20 g / 10...1000 Hz, 6 hours for each of XYZ axes
	Shock	30 g / 6 ms
	Permissible ambient light, lx	30000
	Relative humidity, %	5-95 (no condensation)
	Operating ambient temperature, °C	0...+45
	Storage temperature, °C	-20...+70
Weight (without cables), gram	6800	


Note: System parameters can be changed for a specific task.

6. Example of item designation when ordering

RF096-Dmin/Dmax-L

Symbol	Description
Dmin/Dmax	ID measurement range, mm.
L	Measurement depth, mm.

Example: RF096-35/55-100 - Pipe ID Control System, ID measurement range - 35...55 mm, measurement depth - 100 mm.

5


The system operates as follows.

The measured pipe is installed coaxially with the laser sensor. At the command of an external controller, the laser sensor moves into the hole. The sensor begins to rotate and scans the inner surface of the pipe, transmits the polar coordinates of the surface (distance from the axis of rotation measured by the sensor and the corresponding angle of rotation) to the built-in computer to calculate the required geometric parameters. The result is transmitted to the external controller via PROFINET.

8. Connection

- Connect the system to your controller.
- Connect the power cable to the system.
- Connect the system to 24V DC by using the special power cable.

The block diagram is shown below. In this diagram, I-7580 module is PROFINET IO device of the system, and PLC is S7-1200 from Siemens. The program «Step 7 V11» provided by Siemens does the configuration and communication.




9. Network configuration

Configure the network as shown below:


PC	PLC	I-7580
–	Device name: PLC_1	Device name: i-7580
IP: 192.168.1.210	IP: 192.168.6.211	IP: 192.168.1.212
Mask: 255.255.0.0	Mask: 255.255.0.0	Mask: 255.255.0.0

9.1. PC

1. Select **Start Menu > Control Panel > Network and Sharing Center**. (For Windows 8 and higher, search for **Control Panel**, and select **Network and Internet**).
2. Click **Change adapter settings**.




3. Right-click on **Local Area Connection** and select **Properties**.




7

4. Select **Internet Protocol Version 4 (TCP/IPv4)** and click on **Properties**.



5. Select **Use the following IP address** and enter the IP address, Subnet Mask, Default Gateway and DNS server.

Click **OK** and close the **Local Area Connection Properties** window.




8

9.2. PLC


1. Double-click the **TIA** icon to start **Step 7 V11**.



2. Click **Project view**.




3. Search for accessible devices.




9

4. Select PLC and click the Online & diagnostics button.




5. Set the IP address and the subnet mask.




10

6. Set the device name.




9.3. I-7580 module


1. Search for accessible devices.




2. Select I-7580 module and click the Online & diagnostics button.



3. Set the IP address and the subnet mask.


12

4. Set the device name.



10. GSD import

Please follow the steps to import the GSD file:

Step 1: Get the GSD file

The GSD file can be downloaded from an FTP site:


[ftp://ftp.icpdas.com/pub/cd/fieldbus_cd/profinet/converter/i-7580/gsd/](http://ftp.icpdas.com/pub/cd/fieldbus_cd/profinet/converter/i-7580/gsd/)

Step 2: Import the GSD file


1. Double-click the TIA icon to start Step 7 V11.




2. Click Project view.



3. Select Menu > Options > Install general station description file (GSD).



4. Select and install the GSD file.



14

11. Project setup


Please follow the steps to setup the project:

Step 1: Create the project

1. Double-click the TIA icon to start **Step 7 V11**.




2. Create the project.




Step 2: Project configuration

1. Add the PLC device.


15



2. Select Add new device.




3. Set the PLC name to «PLC_1».




16

4. Set the IP address and the subnet mask for PLC and add the new subnet.




5. Add the I-7580 module.


17



6. Select the PROFINET interface.




7. Set the device name to «i-7580».




18


8. Set the IP address for the I-7580 module.




9. Set the module type for the I-7580 module.






10. Set parameters for the I-7580 module.



11. Compile and download to the device.





12. Communication

12.1. Communication sequence


The I-7580 module basically contains 4 buffers:

- PROFINET IO device input buffer.
- PROFINET IO device output buffer.
- COM port input buffer.
- COM port output buffer.


The PROFINET IO controller basically contains 2 buffers:

- PROFINET IO controller input buffer.
- PROFINET IO controller output buffer.

In the I-7580 module, data is transferred from the COM port input buffer to the PROFINET IO device output buffer, and from the PROFINET IO device input buffer to the COM port output buffer. The data flow is illustrated below.



During each message cycle, the PROFINET IO controller writes the content of its output buffer to the PROFINET IO device input buffer and reads the content of the PROFINET IO device output buffer to its input buffer. The exchange cycle is taking place even though the content of the PROFINET IO controller and PROFINET IO device output buffer has not changed. The data flow between the PROFINET IO controller and the I-7580 module is shown below.



12.2. PROFINET Input Data Area

The maximum input data length of I-7580 is 512 bytes. The first 8 bytes of the received input data are reserved for the communication status. The remaining data in the input data area represents the data packet received from the serial network. The 9th byte therefore shows the first byte of the received serial data.

Byte	Data	Description
0	0x00	I-7580 does not transmit I/O data.
	0x01	I-7580 transmits data to the COM port.
	0x02	I-7580 receives data from the COM port.
1	Error State	Bit 0: Output FIFO overflow Bit 1 : Input FIFO overflow Bit 2 : Output Data loss Bit 3 : Input Data loss Bit 4 : Input Data overflow
2	Length	Received data length (High byte)
3		Received data length (Low byte)
4	Input	Received data count (High byte)
5	Count	Received data count (Low byte)
6	Output	Transmitted data count (High byte)
7	Count	Transmitted data count (Low byte)
8~511	Data	Receive data from the COM port

The I-7580 module has three modes to identify data from two batches of data packet. These modes are: (1) Interval time, (2) Fixed data length, and (3) End character of data.

12.2.1. "Interval time" mode

If the time between two consecutive bytes exceeds the timeout value, the module transfers the data from the COM port input buffer to the PROFINET IO device output buffer. The default timeout value is set to the duration needed to send one data byte. That means if after a time period of one byte no additional data arrives, then the data that is already in the COM port input buffer will be regarded as a data packet.

The interval time between messages arriving at the COM port must be greater than 2 milliseconds.

12.2.2. "Fixed data length" mode

The converter counts the number of bytes arriving at the COM port. If the specified amount of data has entered the serial input buffer, the content is removed from the input buffer and transferred to the PROFINET IO device output buffer. The last string will only be send after a transmit time of three bytes has elapsed. To use this feature, you need to set the "Input fixed length data" parameter to "Enable". The data length has to be defined in bytes 5-6 of the PROFINET output data area (please refer to section "PROFINET Output Data Area").

Fixed Length : 5 (byte 5, 6 of PROFINET output data area)

String arriving at the Com Port:

01	02	03	04	05	06	07	08	09	0A	0B	0C	0D
----	----	----	----	----	----	----	----	----	----	----	----	----

String Count : 3

String 1:

01	02	03	04	05
----	----	----	----	----

String 2:

06	07	08	09	0A
----	----	----	----	----

String 3:

0B	0C	0D
----	----	----

String 3 will only be send after a transmit time of three bytes has elapsed.

23

12.2.3. "End character" mode

As soon as the converter detects the end characters of the incoming serial data stream, it removes the data from the serial receive buffer and transfers it to the PROFINET IO device output buffer of the converter.

If the time interval between two consecutive bytes is longer than the time needed to transmit three bytes, then the module treats this situation as an end of a string.

To use this feature, the "End char of input data" parameter must not be set to "None".

Example 1:

The end character : CR(0x0D)

String arriving at the Com Port:

01	02	0D	03	0D	04	05	06	07	0D
----	----	----	----	----	----	----	----	----	----

String Count : 3

String 1:

01	02
----	----

String 2:

03

String 3:

04	05	06	07
----	----	----	----

Example 2:

The end character : CR(0x0D)

Time interval between two consecutive bytes is longer than the time needed to transmit three bytes

String arriving at the Com Port:

01	02	03	04	0D	05	06	07	08	0D
----	----	----	----	----	----	----	----	----	----

String Count : 3

String 1:

01	02
----	----

String 2:

03	04
----	----

String 3:

05	06	07	08
----	----	----	----

12.3. PROFINET Output Data Area

The maximum output data length of I-7580 is 384 bytes. The first 8 bytes are needed to set the communication behavior of the converter.

Byte	Data	Description
1	0 ~ 255	Data output command.
2	0x01	Control bit – clear all diagnostic messages.
	0x02	Control bit – clear Received data count.
	0x04	Control bit – clear Transmitted data count.
3	Length	Output data length (High byte).
4		Output data length (Low byte).

5	Length	Fixed data length (High byte).
6		Fixed data length (Low byte).
7	0~255	Interval time between the two batches of the data.
8	0~255	Timeout value.
9~384	Data	Output data to COM port.

12.3.1. Data output command (byte 1)

The PROFINET IO Controller is cyclically polling the I-7580 module. The PROFINET IO Controller sends data from its output buffer to the input buffer of the converter. If no new data is put on the PROFINET IO Controller output buffer, the PROFINET IO Controller sends the same data in each polling cycle. Therefore, it is necessary for the converter to detect whether the data arriving at its PROFINET IO device input buffer has already been sent before or is new. The converter recognizes a new data packet when the value of the first byte differs from the previous data packet. A change of the first byte results in an immediate output of the newly arrived data (at the PROFINET IO device input buffer) to the serial COM port.

When the user wants to send a new data packet to the converter, the user should increase progressively the first byte (ex: 0->1, 1->2, 2->3, ..., 255->0), and the converter will send the new data packet to the serial COM port. If the user changes the first byte but doesn't increase progressively it (ex: 0->2, 1->3, 2->5), the converter will send a diagnostic message "Output data - data loss". This message informs the user that the PROFINET data may be loss.



ATTENTION!

The converter will send no data to the connected serial devices if the content of the first byte of two consecutive PROFINET messages is identical. Even if the remaining bytes differ, no message will be forwarded to the COM port. The converter detects a new data packet only by checking the first byte.

12.3.2. Control bit (byte 2)

Bit 0: When this bit is set, all diagnostic messages sent by the I-7580 module will be cleared.

Bit 1: When this bit is set, the I-7580 module sets the **Received data count** to zero (please refer to section "PROFINET Input Data Area").

Bit 2: When this bit is set, the I-7580 module sets the **Transmitted data count** to zero (please refer to section "PROFINET Input Data Area").

Bit 3~7: The remaining bits have to be set to zero.

12.3.3. Output data length (byte 3, byte 4)

The default value for the output data length is 0. It has to be set for every single output command, otherwise no data will be sent to the COM port.

These two bytes determine the number of bytes copied from the I-7580 PROFINET IO device input buffer to the COM port output buffer. This means that regardless of the data length sent by the master, only the number of bytes specified in the third byte will be forwarded to the COM port.

12.3.4. Fixed data length (byte 5, byte 6)


These two bytes determine the length of the response data string. The converter waits until the data arriving at the COM port buffer has reached the specified length.

To use this feature, the "Input fixed length data" parameter has to be set to "Enable".

12.3.5. Interval time (byte 7)

This byte can increase the interval time between two batches of the data packet. It means the converter can delay the data output from PROFINET to the COM port.

Example: Interval time – 15 ms.



12.3.6. Timeout value (byte 8)

The timeout is only relevant for the communication between the I-7580 converter and the serial network. The converter receives the response of the device at the COM port as a continuous data stream. A silent interval in the data stream exceeding the timeout value signals the converter the end of the message and forwards this message to its PROFINET IO device output buffer.

Valid values for the timeout: 0 to 255.

The value "0" represents the minimum value which equals the transmission time of one byte [(start bit+data bit+parity bit+stop bit)/Baudrate].

The value "1" assigns a timeout value of either 1 or 10 milliseconds depending on the chosen unit (1 or 10 ms).

The value "255" represents either 255 milliseconds (time unit: 1 ms) or 2550 milliseconds (time unit:10 ms).



This byte specifies the timeout for the data stream of the serial response. If the multiply responses are expected for every request sent by the converter, then the timeout applies to all these messages.

12.4. Communication between PLC and system

Communication between PLC and system:

Area byte	Data from PLC to System		Data from System to PLC	
	Description	Var Type	Description	Var Type
0	Calibration diameter	Real	Last diameter read average	Real
4		Real	Last diameter read minimum	Real
8		Real	Last diameter read maximum	Real
12	Measurement position (from a zero point of a pipe)	Real		Real
16		Int		Int
18		Int		Int
20		Int		Int
22		Int		Int
24.0	Start calibration command	Bool	Calibration running	Bool
24.1		Bool	Calibration Done	Bool
24.2		Bool	Calibration error	Bool
24.3	Start measure command	Bool	Measure running	Bool
24.4		Bool	Measure Done	Bool
24.5		Bool	Measure error	Bool
24.6	New data transfer	Bool	New data transfer request read	Bool
24.7		Bool	New transfer data read	Bool
25.0	Abort measure	Bool	System error	Bool
25.1	Move to zero	Bool	Move to zero running	Bool
25.2		Bool	Move to zero Done	Bool
25.3		Bool	Move to zero error	Bool
25.4		Bool		Bool
25.5		Bool		Bool
25.6		Bool		Bool
25.7		Bool		Bool

12.4.1. General information

Every system error of the pipe control system must set the **System error** variable.

If this bit is raised up during any measurement, every cycle will be interrupted and measurement results will not be read.

If for any reason PLC sets the **Abort measure** variable during the measurement cycle, the pipe control system must finish the running procedure and move a laser sensor into a safe position. This can be done if the operator checks for any anomaly during the measurement cycle.

12.4.2. Data transfer

- PLC prepares variables with the new data according to production requirements: **Calibration diameter**, **Measurement position**.
- PLC requires to save the new data in the pipe control system by setting the **New data transfer** flag = TRUE and waits until the process is complete.
- The pipe control system sets **New data transfer request read** = TRUE and holds it until all data is read.
- When the pipe control system has finished reading the new data from PLC, it sets **New transfer data read** = TRUE and holds this flag waiting a reply from PLC.
- PLC reads that the pipe control system has completed the procedure and resets **New data transfer** = FALSE.
- The pipe control system resets variables **New data transfer request read** = FALSE and **New transfer data read** = FALSE.

12.4.3. Calibration

- PLC requires to perform the calibration procedure for the pipe control system by **Start calibration command** = TRUE and holds this flag until the process is complete.
- When the pipe control system starts the calibration cycle, it sets **Calibration running** = TRUE and holds it until the process is complete.
- When the pipe control system has completed the calibration process, it sets **Calibration Done** = TRUE and holds it waiting a reply from PLC.
- PLC reads that the pipe control system has completed the procedure and resets **Start calibration command** = FALSE.
- The pipe control system resets variables **Calibration running** = FALSE , **Calibration Done** = FALSE.

12.4.4. Measurement

- PLC requires to make a new measurement by **Start Measure command** = TRUE and holds the flag until the process is complete.
- The pipe control system starts the measurement cycle, sets **Measure running** = TRUE and holds it until the process is complete.
- When the pipe control system has completed the measurement process, it writes variables **Last diameter average**, **Last diameter read minimum**, **Last diameter read maximum**, sets **Measure Done** = TRUE and holds this flag until all the measurement data is read by PLC.
- PLC reads that the pipe control system has completed the measurement procedure and resets **Start Measure command** = FALSE.
- The pipe control system resets variables **Measure running** = FALSE, **Measure Done** = FALSE.

12.4.5. Go to zero

- PLC requires the pipe control system to go to a zero position, sets **Move to zero** = TRUE and holds this flag until the process is complete.
- The pipe control system starts to move a laser sensor to a zero position, sets **Move to zero running** = TRUE and holds the flag until the process is complete.
- When the pipe control system has completed the process, it sets **Move to zero Done** = TRUE and holds it waiting a reply from PLC.




- PLC reads that the pipe control system has completed the procedure and resets **Move to zero** = FALSE.
- The pipe control system resets variables **Move to zero running** = FALSE, **Move to zero Done** = FALSE.

12.5. Communication tests


The user can perform communication tests by connecting the system to the PC using the Ethernet connector.

Step 1: Run SSH client

1. On the PC, we use "PuTTY" to test.



2. Enter a host name 192.168.1.100 as shown below, and click **Connect (Open)**.



Step 2: Work with terminal

1. Write Login and Password:

Login: pi

Password: raspberry

2. After 5-10 seconds, when you see a picture as shown below (the process is restarted for a new session), press **Ctrl+C** to end it.

29

```
pi@raspberrypi: ~
pi@192.168.1.100's password:
Linux raspberrypi 4.14.79-v7+ #1159 SMP Sun Nov 4 17:50:20 GMT 2018 armv7l

The programs included with the Debian GNU/Linux system are free software;
the exact distribution terms for each program are described in the
individual files in /usr/share/doc/*copyright.

Debian GNU/Linux comes with ABSOLUTELY NO WARRANTY, to the extent
permitted by applicable law.
Last login: Tue Dec 11 13:24:21 2018 from 192.168.1.2

SSH is enabled and the default password for the 'pi' user has not been changed.
This is a security risk - please login as the 'pi' user and type 'passwd' to set
a new password.

pi@raspberrypi:~ $ 
pi@raspberrypi:~ $ 2018-12-11 13:26:17 started
2018-12-11 13:26:17      plc port open
2018-12-11 13:26:17      motor connected, type 99, sn 118
2018-12-11 13:26:17      sensor connected, assembly 14, sn 55, range 18
2018-12-11 13:26:17      started thread proc
^C
pi@raspberrypi:~ $ 
```

3. Enter the command «ps -a» to check if the «run» process is exited. If the process still works, kill it by the command «kill -9 XXX», where XXX – the number of the «run» process.

```
pi@raspberrypi:~ $ ps -a
  PID TTY      TIME CMD
  501 ttys000    00:00:00 bash
  705 pts/0    00:00:02 run
  709 pts/0    00:00:00 ps
pi@raspberrypi:~ $ kill -9 705
```

4. Run the test process: «LD_LIBRARY_PATH=. ./run_contest».

```
pi@raspberrypi:~ $ LD_LIBRARY_PATH=. ./run_contest
2018-12-11 13:30:37      started
2018-12-11 13:30:37      plc port open
2018-12-11 13:30:37      motor connected, type 99, sn 118
2018-12-11 13:30:37      sensor connected, assembly 14, sn 55, range 18
2018-12-11 13:30:37      started thread proc
1) data transfer | 2) calibration | 3) measure | 4) move zero? 
```

5. Make a selection by typing a number [1-4]:

1 - Test the data transfer command by setting the measurement position to 10.5 mm.

2 - Test the calibration process.

3 - Test the measurement process.

4 - Test the "move to zero" process.

12.6. Diagnostic messages

The I-7580 module has two types of diagnostic messages: "Output Data Error" and "Input Data Error".

Type	Description
Output Data Error	FIFO overflow.
	Data loss.
Input Data Error	FIFO overflow.

12.6.1. Output Data Error

1. When the PROFINET network speed is higher than the serial network speed and the PROFINET IO controller continuously transmits data to the I-7580 module, the output buffer of the I-7580 module will overflow, and the I-7580 module will send a diagnostic message "Output Data Error – FIFO overflow".
2. When the I-7580 module receives the data output command (first byte of the output data area, please refer to section "PROFINET Output Data Area") from the PROFINET IO controller and the command is not increased continuously (for example: 0->1, 1->2 ... 254->255, 255->0), the I-7580 module will send a diagnostic message "Output Data Error – Data loss" to the PROFINET IO controller.

12.6.2. Input Data Error

1. When the serial network speed is higher than the PROFINET network speed and the serial device continuously transmits data to the I-7580 module, the input buffer of the I-7580 module will overflow, and the I-7580 module will send a diagnostic message "Input Data Error – FIFO overflow".
2. When the I-7580 module cannot receive data in time from the COM port, it will send a diagnostic message "Input Data Error – Data loss". Please refer to section "PROFINET Input Data Area".
3. The maximum input data length for the COM port of the I-7580 module is 506 bytes. When the COM port of the I-7580 module receives data larger than 506 bytes, it will send a diagnostic message "Input Data Error – Data overflow".

13. Intended use

13.1. Preparation for use

- Check the condition of the output window of a laser sensor and, if necessary, wipe it with a soft cloth.
- Rotate a laser sensor by hand and check the smooth progress.
- Check the cables and power supply.
- Make sure that the network settings are correct.
- Switch on the system.
- Run the test procedures. Please refer to section [12.5. "Communication tests"](#).

13.2. Measurements

Run the sequence of commands described in section [12.4. "Communication between PLC and system"](#).

14. Technical support

Technical assistance related to incorrect operation of the system and to problems with a service program is free. Requests for technical assistance should be addressed at support@riftek.com.

15. Warranty policy

Warranty assurance for the Pipe ID Control System RF096-35/55-100 Series - 24 months from the date of putting in operation; warranty shelf-life - 12 months.

16. Revisions

Date	Version	Description
12.12.2018	1.0.0	Starting document.

17. Distributors

AUSTRIA

MBM Industry & Rail Tech GmbH
RAILWAY INSTRUMENTS ONLY
 Tullnerbachstraße 36,
 A-3002 Purkersdorf, Austria
 Tel: +43 2231 66000
 Fax: +43 2231 66000 12
office@mbm-industrietechnik.at
www.mbm-tech.at

AUSTRALIA

Applied Measurement Australia Pty Ltd
RAILWAY INSTRUMENTS ONLY
 Thornton Plaza, Unit 5,
 27 Thornton Crescent, Mitcham
 VIC 3132, Australia
 Tel: +61 39874 5777
 Fax: +61 39874 5888
sales@appliedmeasurement.com.au
www.appliedmeasurement.com.au

BENELUX

Althen Sensors & Controls BV
 Vlietweg 17a
 2266KA Leidschendam
 The Netherlands
 Tel: +31 70 3924421
 Fax: +31 70 3644249
sales@althen.nl
www.althensensors.com
www.althencontrols.com

BULGARIA, HUNGARY

RMT Ltd.
 R Zahradni 224
 739 21 Paskov, Czech Republic
 Tel: +420 558640211
 Fax: +420 558640218
rmt@rmt.cz
www.rmt.cz

BRAZIL

CAPI Controle e Automação Ltda
 Rua Itororó, 121, CEP 13466-240
 Americana-SP, Brazil
 Tel: +55 19 36047068
 Fax: +55 19 34681791
capi@capicontrole.com.br
www.capicontrole.com.br

CHILE

Verne SpA
 Apoquindo 2818, oficina 31,
 Las Condes, Santiago, Chile
 Tel: +56 2 228858633
info@verne.cl
jsaavedra@verne.cl
www.verne.cl

CHINA

Beijing Gemston Mechanical & Electrical Equipment Co., Ltd
 Room 613, Anfu Mansion, Fengtai District, Beijing, China
 Tel: +86 10 6765 0516
 Fax: +86 10 6765 6966
 Mobile: +86 137 1755 1423
dh0526@163.com
www.baoft.cn

CHINA

JRKtech Co., Ltd.
 1F, Building 9, 100 Xianlie Rd., Guangzhou, China
 Tel: +86 755 85267190/
 +86 15989362481
 Fax: +86 755 85267190
shengz_k@163.com
www.jrktech.com

CHINA

Shanghai micron-metrology com., Ltd.
 Room 602 unit 4, lane 399,
 Mudan road, Pudong New district
 Shanghai, China
 Tel: +86-21-68416510
sales@micron-metrology.cn
www.micron-metrology.cn

CHINA

Zhenshangyou Technologies Co., Ltd.
Rm 2205-2210, Zhongyou Hotel
1110 Nanshan Road, Nanshan
District 518054 Shenzhen, China
Tel: +86 755-26528100/8011/8012
Fax: +86 755-26528210/26435640
info@51sensors.com
www.51sensors.com

CZECH REPUBLIC

RMT Ltd.
Zahradni 224
739 21 Paskov, Czech Republic
Tel: +420 558640211
Fax: +420 558640218
rmt@rmt.cz
www.rmt.cz

FINLAND

TERÄSPYÖRÄ-STEELWHEEL OY
RAILWAY INSTRUMENTS ONLY
Juvan teollisuuskatu 28
FI-02920 ESPOO, Finland
Tel: +358 400 422 900
Fax: +358 9 2511 5510
steelwheel@steelwheel.fi
www.teraspypora.fi

FRANCE

BLET Measurement Group S.A.S.
1 avenue du Président Georges Pompidou, 92500 Rueil Malmaison, France
Tel: + 33(0)1 80 88 57 85
Fax: +33(0)1 80 88 57 93
technique@blet-mesure.fr
www.blet-mesure.fr

GERMANY

Disynet GmbH
Breyeller Str. 2
41379, Brueggen
Tel: +49 2157 8799-0
Fax: +49 2157 8799-22
disynet@sensoren.de
www.sensoren.de

GERMANY

Finger GmbH & Co. KG
OPTICAL MICROMETERS ONLY
Sapelloh 172,
31606 Warmse, Germany
Tel: +49 5767 96020
Fax: +49 5767 93004
finger@finger-kg.de
www.finger-kg.de

32
GERMANY

Hylewicz CNC-Technik SHTRIKH-2 ONLY
Siemensstrasse 13-15,
47608 Geldern, Germany
Tel: +49 2831 91021-20
Fax: +49 2831 91021-99
info@cnc-step.de
www.cnc-step.de

INDIA

Pragathi Solutions
#698, 5th Main, 8th Cross,
HAL 3rd Stage,
New Tippasandra Road,
Bangalore, 560075, India
Tel: +91 80 32973388
Tel/fax: +91 80 25293985
Mobile: +91 9448030426/
+919448492380
sales@pragathisolutions.in
arghya@pragathisolutions.in
www.pragathisolutions.in

INDIA

Paragon Instrumentation Engineers Pvt. Ltd.
RAILWAY INSTRUMENTS ONLY
200, Station Road,
Roorkee, 247 667, India
Tel: +91-1332-272394
tanuj@paragoninstruments.com
www.paragoninstruments.com

INDONESIA

PT. DHAYA BASWARA SANIYASA
Botanic Junction Blok H-9 NO. 7
Mega Kebon Jeruk, Joglo
Jakarta 11640, Indonesia
Tel: + 62 21 29325859
management@ptdbs.co.id

IRAN

Novin Industrial Development Grp.
Tel: +98 21 44022093-6
Fax: +98 21 43858794
Mobile: +98 9123207518
info@novnid.com
www.novnid.com

ISRAEL

Nisso Dekalo Import Export LTD
1 David Hamelech Street
Herzia 46661 Israel
Tel: +972-99577888
Fax: +972-99568860
eli@fly-supply.net
www.fly-supply.net
www.aircraft-partsupply.com

ITALY

FAE s.r.l.
Via Tertulliano, 41
20137 Milano, Italy
Tel: +39-02-55187133
Fax: +39-02-55187399
fae@fae.it
www.fae.it

JAPAN

Tokyo Instruments, Inc.
6-18-14 Nishikasai, Edogawa-ku,
Tokyo, 134-0088 Japan
Tel: +81 3 3686 4711
Fax: +81 3 3686 0831
f_kuribayashi@tokyoinst.co.jp
www.tokyoinst.co.jp

LATVIA, ESTONIA

SIA "SOLARTEX"
RAILWAY INSTRUMENTS ONLY
Duntes 15a, 5th floor, office B7
Riga, Latvia
Tel.: +371 67 130 787
solartex@inbox.lv

MALAYSIA

OptoCom InstruVentures
 H-49-2, Jalan 5, Cosmoplex
 Industrial Park, Bandar Baru
 Salak Tinggi, Sepang, Malaysia
 Tel: 603 8706 6806
 Fax: 603 8706 6809
optocom@tm.net.my
www.optocom.com.my

NORWAY

Salitec AS
 PB 468,
 N-1327 Lysaker
 Tel.: +47 23 891015
 Fax: +47 92101005
mail@salitec.no
www.salitec.no

PERU

Verne Perú S.A.C.
 Las Codornices 104,
 Surquillo, Lima, Peru
 Tel/fax: +51 992436734
info@verne.cl
www.verne.cl

POLAND

MTL ASCO Sp. z o.o.
RAILWAY INSTRUMENTS ONLY
 ul. Wielowiejska 53 44-120
 PYSKOWICE (k/ GLIWIC),
 Poland
 Tel: + 48 32 230 45 70
 Fax: + 48 32 332 70 14
rail@ascorail.eu
www.ascorail.eu

PORTUGAL

Camifer Produtos Ferroviários
RAILWAY INSTRUMENTS ONLY
 Oeiras, Portugal
 Phone: +351 21 584 4348
 Phone: +351 918 787 498
camifer@camifer.pt
www.camifer.pt

RUSSIA

Sensorika-M LLC
 Dmitrovskoye shosse 64-4
 127474, Moscow, Russia
 Tel: +7 499 487 0363
 Fax: +7 499 487 7460
info@sensorka.com
www.sensorka.com

RUSSIA

Diesel-test-Komplekt LLC
 620030, Karjernaya St, 16
 Ekaterinburg, Russia
 Tel/fax: +7 343 2227565
 Tel/fax: +7 343 2227370
mail@d-test.ru
www.d-test.ru

SERBIA, SLOVAKIA

RMT Ltd.
 Zahradni 224
 739 21 Paskov, Czech Republic
 Tel: +420 558640211
 Fax: +420 558640218
rmt@rmt.cz
www.rmt.cz

SOUTH AFRICA

Ratcom Enterprise Pty Ltd
 CSIR BUILDING 35, Office 78
 Meiring Naude Road, Brummeria
 Pretoria, 0084 South Africa
 Tel: + 27 12 841 2032
 Fax: + 27 86 225 0650
info@ratcom.co.za
www.ratcom.co.za

SOUTH KOREA

PROSEN. CO., LTD
 M-1001, Songdo techno park IT
 center, 32, Songdogwahak-ro,
 Yeonsu-gu, Incheon, 21984,
 Republic of Korea
 Tel: +82-32-811-3457
 Fax: +82-32-232-7458
trade@prosen.co.kr
www.prosen.co.kr

SOUTH KOREA

BS Holdings
 B-201,Wonpogongwon 1ro,
 59 Danwon-gu, Ansan-si,
 Gyeonggi-do, 15455,
 Republic of Korea
 Tel: +82-31-411-5011
 Fax: +82-31-411-5015
bsh5011@hanmail.net
www.lasersolution.co.kr

SPAIN

Iberfluid Instruments S.A.
 C/ Botanica, 122
 08908 L'Hospitalet de Llobregat,
 Barcelona
 Tel: +34 93 447 10 65
 Fax: +34 93 334 05 24
myct@iberfluid.com
www.iberfluid.com

SWITZERLAND

ID&T GmbH
 Gewerbestrasse 12/a
 8132 Egg (Zurich), Switzerland
 Tel: + 41 44 994 92 32
 Fax: + 41 44 994 92 34
info@idtlaser.com
www.idtlaser.com

SWEDEN, DENMARK

BLConsult
 Ryssbält 294,
 95 291 KALIX, Sweden
 Mobile: +46 70 663 19 25
info@blconsult.se
www.blconsult.se

SWEDEN, DENMARK

Latronix AB
 Propellervagen 10,
 183 62 Täby, Sweden
 Tel.: +46 08-446 48 30
 Fax: +46 08-446 48 39
sales@latronix.se
www.latronix.se

TAIWAN
Nano-Trend Technology Co., Ltd.

No.365-6, Zhongshan Rd., Sanxia Dist., New Taipei City 23741, Taiwan (R.O.C.)
 Tel: +886-2-8671-9560
 Fax: +886-2-8671-0084
nt@nano-trend.com
www.nano-trend.com

THAILAND
Advantech Solution Co.,Ltd.

20/170 Motorway Rd., Kwang Pravet, Khet Pravet, Bangkok, Thailand 10250
 Tel: +662-1848705
 Fax: +662-1848708
sales@advantechsolution.com
www.advantechsolution.com

TURKEY
TEKMA Mühendislik A.S.

Cevizli Mh. M. Kemal Cd., Hukukçular Towers, A-Blok, No: 66-A/39 Kartal – İstanbul
 Tel: +90 216 970 1318
 Tel: +90 850 840 2334
info@tekma.eu
www.tekma.eu

UKRAINE
KODA

Frunze st 22
 61002, Harkov, Ukraine
 Tel/fax: +38 057 714 26 54
mail@koda.com.ua
www.koda.com.ua

**UNITED KINGDOM,
IRELAND**
Ixthus Instrumentation Ltd

The Stables, Williams' Barns Tiffield road, Towcester, Northants
 Tel: +44 1327 353437
 Fax: +44 1327 353564
info@ixthus.co.uk
www.ixthus.co.uk

USA, CANADA, MEXICO
**International Electronic
Machines Corporation**

RAILWAY INSTRUMENTS ONLY
 850 River Street, Troy,
 New York, USA
 Tel: +1 518 268-1636
 Fax: +1 518 268-1639
marketing@iem.net
wwwием.net

USA, CANADA, MEXICO
**Acuity Products of Schmitt
Industries, Inc.**

2765 NW Nicolai Street
 Portland, OR, 97210, USA
 Tel: +1 503 227 7908
 Fax: +1 503 223 1258
sales@acuitylaser.com
www.acuitylaser.com